


RESTORATION IN UNPAVED AREAS

A. TOPSOIL AND SEEDING

1. Topsoil shall be placed in areas where grass has been disturbed by the Contractor's operations. Depth of topsoil shall be four inches (4") minimum. Topsoil salvaged and stockpiled during trench and structure excavation may be used for this purpose. When top soiling, all materials and methods of construction shall meet the provisions of MD SHA Standards, Section 701, 702, 703, 704, 705, and 920. If directed, the Contractor shall have the topsoil tested by a State certified laboratory and shall submit certification that topsoil meets the specified standard. Topsoil shall be clean, free of roots, stones, and other debris.
2. Seeding shall consist of furnishing and placing seed and soil supplements on top soiled areas and at any other location, as directed by the Engineer. When seeding, all materials and methods of construction shall meet the provisions of MD SHA Standards, Section 705 and 920.
3. Fertilizer shall be a recognized commercial fertilizer conforming to MD SHA standards, Section 920.
4. Mulch shall be applied on disturbed areas with slopes less than 3 to 1. Mulch for these areas shall consist of straw mulch as specified in MD SHA Standards, Section 705. Mulching of areas where slopes equal or exceed 3:1 shall utilize curlex or equal.

<p>APPROVAL</p>  <p>TOWN ENGINEER</p> <p>2/25/09 DATE</p>	<p>REVISED</p>	<p>TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS</p> <p>RESTORATION NOTES</p>
<p>ISSUED: FEB 25, 2009</p>		<p>STANDARD NO. PW 1.11</p>

Y:\samba\CIVIL\STANDARD\DETAILS\6000 City Details\Easton MD\DETAILS\PW-1.11.DWG May 27, 2009 - 8:41am, (batn)