



NOTES:

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:
BITUMINOUS CONCRETE
SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM
BASE COURSE 2.5" 'BC' OR SUPERPAVE 19.0MM
3. SUBBASE:
6" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED PROCTOR METHOD.
4. SUBGRADE:
COMPACT APPROVED SUBGRADE TO 95% OF ASTM D1557 - SUBGRADE MATERIAL SHALL HAVE A MINIMUM CBR OF 10 AND BE APPROVED BY THE TOWN ENGINEER.
5. ENTIRE 60' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. 35' ROAD WIDTH IS MEASURED FROM FLOWLINE FOR STANDARD CURB AND GUTTER OR MOUNTABLE CURB. SEE STANDARD PW 2.03 FOR MOUNTABLE CURB DETAIL.

APPROVAL

[Signature] 2/25/09
TOWN ENGINEER DATE

REVISED

MAY 1, 89
AUG. 1, 94
MAR 1, 98
SEP 1, 02
FEB 1, 06

TOWN OF EASTON
AND
EASTON UTILITIES
STANDARD DETAILS
RESIDENTIAL SUB-COLLECTOR
STREET

ISSUED: MAY 1, 1986 FEB 25, 09 STANDARD NO. PW-1.01