



NOTES:

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:
BITUMINOUS CONCRETE
SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM
BASE COURSE 2.5" 'BC' OR SUPERPAVE 19.0MM
3. SUBBASE:
6" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED PROCTOR METHOD.
4. SUBGRADE:
COMPACT APPROVED SUBGRADE TO 95% OF ASTMD1557 - SUBGRADE MATERIAL SHALL HAVE A MINIMUM CBR OF 10 AND BE APPROVED BY THE TOWN ENGINEER.
5. ENTIRE 20' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. MINIMUM RATE OF GRADE FOR ALLEYS SHALL BE 1.00%.

APPROVAL

[Signature] 2/25/09
TOWN ENGINEER DATE

REVISED

AUG. 1, 94
JULY 1, 98
SEP 1, 02
JAN 1, 07
FEB 25, 09

TOWN OF EASTON
AND
EASTON UTILITIES
STANDARD DETAILS
RESIDENTIAL ALLEY

ISSUED: MARCH 1, 1994

STANDARD NO. PW-1.03