



**NOTES:**

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:  
BITUMINOUS CONCRETE  
SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM  
BASE COURSE 4" 'BC' OR SUPERPAVE 19.0MM, PLACED IN TWO (2) 2" COURSES.
3. SUBBASE:  
SHA BRG SUBBASE PLACED AND COMPACTED IN TWO (2) COURSES OR  
9" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED PROCTOR METHOD.
4. SUBGRADE:  
COMPACT APPROVED SUBGRADE TO 95% OF ASTM D1557 - SUBGRADE MATERIAL SHALL HAVE A MINIMUM CBR OF 10 AND BE APPROVED BY THE TOWN ENGINEER.
5. ENTIRE 60' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. 36' ROAD WIDTH IS MEASURED FROM FLOWLINE FOR STANDARD CURB AND GUTTER OR MOUNTABLE CURB. SEE STANDARD PW 2.03 FOR MOUNTABLE CURB DETAIL.

APPROVAL

*[Signature]* 2/25/09  
TOWN ENGINEER DATE

REVISED

MAY 1, 89  
AUG. 1, 94  
MAR 1, 98  
SEP 1, 02  
FEB 1, 06

TOWN OF EASTON  
AND  
EASTON UTILITIES  
STANDARD DETAILS

COMMERCIAL LOCAL STREET

ISSUED: MAY 1, 1986

FEB 25, 09

STANDARD NO. PW-1.04