



NOTES:

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:
 BITUMINOUS CONCRETE
 SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM
 BASE COURSE 4" 'BC' OR SUPERPAVE 19.0MM, PLACED IN TWO (2) 2" COURSES.
3. SUBBASE:
 SHA BRG SUBBASE PLACED AND COMPACTED IN TWO (2) COURSES OR
 9" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED
 PROCTOR METHOD.
4. SUBGRADE:
 COMPACT APPROVED SUBGRADE TO 95% OF ASTM D1557 - SUBGRADE
 MATERIAL SHALL HAVE A MINIMUM CBR OF 10 AND BE APPROVED BY THE TOWN
 ENGINEER.
5. ENTIRE 60' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. 44' ROAD WIDTH IS MEASURED FROM FLOWLINE FOR STANDARD CURB AND
 GUTTER OR MOUNTABLE CURB. SEE STANDARD PW 2.03 FOR MOUNTABLE CURB
 DETAIL.

APPROVAL

[Signature] 2/25/09
 TOWN ENGINEER DATE

REVISED

MAY 1, 89
 AUG. 1, 94
 MAR 1, 98
 SEP 1, 02
 FEB 25, 09

TOWN OF EASTON
 AND
 EASTON UTILITIES
 STANDARD DETAILS

COMMERCIAL COLLECTOR STREET

ISSUED: MAY 1, 1986

STANDARD NO. PW-1.05