



NOTES:

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:
BITUMINOUS CONCRETE
SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM
BASE COURSE 2.5" 'BC' OR SUPERPAVE 19.0MM
3. SUBBASE:
6" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED PROCTOR METHOD.
4. SUBGRADE:
COMPACT APPROVED SUBGRADE TO 95% OF ASTM D1557 - SUBGRADE MATERIAL SHALL HAVE A MINIMUM CBR OF 10 AND BE APPROVED BY THE TOWN ENGINEER.
5. ENTIRE 60' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. MOUNTABLE CURB OR 2' WIDE DOUBLE SURFACE TREATMENT MAY BE REQUIRED AT THE DISCRETION OF THE TOWN ENGINEER.

APPROVAL

[Signature]
TOWN ENGINEER

4/25/09
DATE

REVISED

MAY 1, 89

AUG. 1, 94

MAR 1, 98

AUG. 1, 01

SEP 1, 02

TOWN OF EASTON
AND
EASTON UTILITIES
STANDARD DETAILS

RESIDENTIAL COLLECTOR STREET

ISSUED: MAY 1, 1986

FEB 25, 09

STANDARD NO. PW-1.02